Tube Installation Manual

All works to be carried out by a qualified electrician according to AS/NZ 3000.

Requirements for **new luminaires (including modified luminaires)**

1. A new luminaire must be safe and should comply with safety standard AS/NZS 60598.1 and any applicable part 2 of that series of safety standards.

2. A new luminaire should be marked with a warning label that is visible whilst replacing lamps. This warning label should be legible and indelible and show the intent of:
***'Warning - not for use with any fluorescent lamps, use only <Brand> <Model Number> <Type> Lamp'*.**

3. A new luminaire should have a fuse to protect against short circuits. This fuse should:

- **be of the HRC type and the new luminaire shall have a fuse replacement rating label;**
- **be of suitable rating;**
- **not be accessible when replacing the lamp;**
- **be accessible only with the use of a tool.**

4. Where a luminaire is modified to use a LED Tube or T8/T5 fluorescent lamp adaptor, the luminaire must continue to be safe if a T8 fluorescent lamp is re-installed, although it

- does not have to function.
- Warranty is void if alterations/serviced/defaced to this product is made other than an authorized representative of AliteLED

5. Installation guide for single-end input LED tube

- **Installation with electronic ballast**



- **Installation with magnetic ballast**



Email:sales@aliteled.com Phone :(03) 9841 8734
ABN: 5045655354 www.AliteLED.com.au